



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-LifeLight
Date: 7 June 2021
We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the CLIFE-HV and following associated product codes

CLIFE-uu-ww-xx-zz-yy
CLIFE-SMS-xx-yy
CLIFE-SM-vv-ww-xx-yy
CLIFE-WPPOD-CKIT-xx

LLIFE-uu-ww-xx-zz-yy
LLIFE-SMS-xx-yy
LLIFE-SM-vv-ww-xx-yy
LLIFE-WPPOD-CKIT-xx

Where,

xx = Blank	Manual Test/Clevertest Plus (CTP)
xx = ZW	Zoneworks
xx = HV	Zoneworks XT HIVE
xx = DATA	Zoneworks DATA
xx = DALI	DALI Registered
yy = Blank	White Housing Colour
yy = BLK	Black Housing Colour
yy = DULSN4H4	Dulux Stepney Custom Housing Colour
yy = RAL1013	RAL1013 Custom Housing Colour
yy = RAL9006	RAL1013 Custom Housing Colour

zz = Blank	Standard IEC Cable
zz = F3C	Custom 3-Core Cable
zz = F5C	Custom 5-Core Cable
zz = NCIL	Status LED shows only Red colour
zz = 4HR	Extra LP Battery

ww = Blank	Standard Lens
ww = CL	Lifelight Head with Corridor Lens version
ww = 2CL	2 x Lifelight Heads with Corridor Lenses version

uu = Blank	Non-splashproof
uu = RECSP	Splashproof version
uu = SMPC	Surface Mount Polycarbonate
uu = TP	Tamper Proof

vv = Blank	Non-weatherproof
vv = WP	Weatherproof version



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

The above products meet requirements of the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce
National Systems and Engineering
Manager

