



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-LIFELIGHTPRO
Date: 26 October 2021
We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the CLIFE-PRO-HV and the following associated product codes

aLIFeB-PRO-cc-dd-ee-ff-gg-hh

aLIFeB-PRO-cc-dd-ee-ff-SQ-gg-hh

aLIFeB-PRO-dd-ee-ff-SPOT-gg-hh
aLIFeB-PRO-SMS-dd-ee-ff-SPOT-gg-hh

aLIFeB-PRO- RECSP-dd-ee-ff-gg-hh

aLIFeB-PRO-SMS-dd-ee-ff-gg-hh

aLIFeB-2PRO-SMS-dd-ii-gg

aLIFeB-PRO-SMC-dd-ee-gg-hh
aLIFE-PRO-SMC-185H-dd-REM-4HR-gg-hh

aLIFeB-PRO-SM-cc-dd-ee-gg-hh

aBS2N-dd
aBS4N-dd

Where,

a = L L10 Battery
a = C LP Battery

b = Blank Non-maintained
b = M Maintained

cc = Blank Non-weatherproof
cc = WP Weatherproof version

dd = Blank Manual Test/Clevertest Plus (CTP)
dd = ZW Zoneworks XT
dd = HV Zoneworks XT HIVE
dd = HVEXTA Zoneworks XT HIVE with External Dipole Antenna
dd = DATA Zoneworks DATA
dd = DALI DALI Registered

ee = Blank Standard fitting
ee = 4HR 4-hour runtime fitting

ff = Blank Standard Lifelight Pro Head
ff = IPREM Lamp head in a Remote Weatherproof Enclosure
ff = IPREMTBCG IPREM version with Test Button and Status Indicator on WP Enclosure
ff = NCIL No charge indicator LED
ff = RECWP Lamp head in a recessed Weatherproof enclosure
ff = REM Lamp head in a Remote Enclosure
ff = TP Lamp head with tamperproof Screws
ff = TP-D Lamp head with tamperproof Screws and Dome
ff = WPPOD-KIT Weatherproof POD version



RCM DECLARATION OF CONFORMITY

gg = Blank
gg = BLK
gg = WHT
gg = "Custom colour code"

Normal White colour version
Custom Black colour version
Custom White colour version
Custom defined colour code

hh = Blank
hh = UPS

Standard fitting
Changeover Central Supplied from a UPS (240V AC)

ii = 600
ii = 1200

2ft batten version
4ft batten version

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

The above products meet requirements of the following standards:

AS/NZS 2293.3:2018 Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs

AS 60598.2.22:2019 Luminaires – Part 2.22: Particular requirements – Luminaires for emergency Lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017 Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce
National Systems and Engineering
Manager

